



Certificate

Nr. 420.01C03

MI Nutra-Lite

Plant with active sludge in Sequencing Batch Reactor (SBR) and primary settlement

Marsh Industries Limited

Units 3-13 Addington Park Industrial Est., NN14 4AS Northants, UK

EN 12566-3:2005+A2:2013, Annex B: Treatment efficiency test

Small wastewater treatment systems for up to 50 PT – Part 3:
Packaged and/or site assembled domestic wastewater treatment plants

Detailed results and information on the test are provided in test report PIA2024-420B06.

Extract of performance details (EN 12566-3, Annex B: Treatment efficiency test)

Organic daily load (influent, nominal)	0.20 kg BOD ₅ /d		
Hydraulic daily load (nominal)	0.6 m ³ /d		
Treatment efficiency (nominal)		Efficiency	Effluent
		COD	33 mg/l
		BOD ₅	4 mg/l
		TN _b *	11.1 mg/l
		NH ₄ -N*	0.5 mg/l
		P _{tot}	6.0 mg/l
		SS	11 mg/l
Electrical consumption (nominal)			0.7 kWh/d
Number of desludging (30 weeks testing EN 12566-3 without desludging)			2 after 30 week test cycle
Number of maintenance operations during the test (without start-up phase)			0

* determined for temperatures $\geq 12^{\circ}$ C in the bioreactor

Tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH
Hergenrather Weg 30
52074 Aachen, Germany

This certificate is for information purposes only and replaces neither the related test report nor the declaration of performance or the CE marking. The results relate only to the tested object.

PIA – Sustainable Certification

geprüft – tested – teste

September 2024, Dipl.-Ing. Gabriel Schatzki
Head of department "Wastewater Treatment"



Notified Body
No.: 1739



Certified according to
ISO 9001:2015